

CERTIFICATE

KEMA No.: **2120393.03**

Issued to:

Applicant:

Lamp 83

Yahya Kemal Mahallesi

34410, KAGITHANE/ISTANBUL, Turkey

Manufacturer/Licensee:

Lamp 83

Yahya Kemal Mahallesi

34410, KAGITHANE/ISTANBUL, Turkey

Products : recessed luminaires for metal-halide lamps

Trade name : LAMP83

Types : L DL 8002002



The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standards EN 60598-1:2004 and EN 60598-2-2:1996;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2114339

KEMA hereby grants the right to use the ENEC KEMA-KEUR certification mark.

The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.

This certificate is issued on: November 6, 2008 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

drs. G.J. Zoetbrood
Managing Director

J. Bronsvort
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	:	recessed luminaires for metal-halide lamps
trade name	:	LAMP83
types	:	L DL 8002002
rated voltage	:	230 V
nature of supply	:	ac
rated frequency	:	50 Hz
rated input	:	70 W
lamp type	:	HCI-TS
class	:	I
degree of protection	:	IP20
description	:	recessed downlight luminaires for fluorescent lamps with decorative glass

Additional information

- Luminaires are provided with F-marking.

TESTS**Test requirements**

EN 60598-1:2004 + A1:2006
EN 60598-2-2:1996 + A1:1997

Test result(s)

The test results are laid down in KEMA test file 2120393.03.

Conclusion

The examination proved that all test requirements were met.

Tested by : H.J. Brouwer

Checked by : P.G.M. Roelofs

Factory location

Lamp 83,
Yahya Kemal Mahallesi, 34410, KAGITHANE/ISTANBUL, Turkey

List of components

Component	trade name	type/model	approval mark ¹⁾
ballast	OSRAM	PTI 70/220-240I 220-240V, 50-60 Hz	ENEC
connector	Adels	LK980 16/450	ENEC
lampholder	BJB	25.809 2/1000, T180	ENEC
wiring	Basoglu	H05SS-F 9x0,75 mm ²	TSE-HAR
wiring, internally	Basoglu	- derived from H05SS-F cable	VDE
¹⁾ * indicates a component tested as part of the appliance			